Sam D. Heaton Fire Chief

Randy Crider Deputy Fire Chief Jimmy Taylor Deputy Fire Chief 1595 County Services Pkwy. Marietta, GA 30008-4021 www.cobbfire.org



Cobb County Fire & Emergency Services

Tom Simler Fire Marshal tom.simler@cobbcounty.org
Jay Westbrook Deputy Fire Marshal jay.westbrook@cobbcounty.org
phone: (770) 528-8310 • fax: (770) 528-8320

Personal Care Homes Certificate of Occupancy Procedures

- 1. Call 770-528-8310 for a plan review appointment. Bring four (4) sets of plans to the Fire Marshal's Office for review. You must also complete the Residential Care form. Personal Care Home plans may be done on 8 ½ X 11 paper provided the following items are shown:
- Dimensions for the overall space and dimensions for each room
- All doors and windows including dimensions of each
- Emergency lighting and exit sign locations
- Fire extinguishers
- Fire alarm devices
- Fire alarm and/or sprinkler system work will require separate plans to be submitted by a licensed subcontractor once you obtain your building permit.

Listed below is additional information that is required for 4 or more people.

- > Site plan showing location of fire hydrant with distance from the structure to the hydrant.
- Water flow test of closest hydrant minimum flow 1500 gpm @ 20 psi.
- ➤ To schedule a water flow test you can call the following: if your structure is in Cobb County or the city of Kennesaw call the Cobb County Water Department at 770-419-6328, or if you are in the City of Powder Springs call 770-943-8010.
- 2. Once the Fire Marshal's Office approves your plans, take the approved plans to the Cobb County Building Department Plan Review Office (770-528-2078), **or** if you are in the Cities of Acworth (770-974-2032), Kennesaw (770-429-4554), or Powder Springs (770-943-1666), you will need to take the approved plans to their Building Department in order to purchase a permit.
- 3. Call for appropriate field inspections from the Building Department, Cobb County (770-528-2073), Acworth (770-974-2032), Kennesaw (770-429-4554), Powder Springs (770-943-1666), and the Fire Marshal's Office at (770-528-8310).
- 4. A Certificate of Occupancy will be issued once <u>all</u> Fire Marshal and Building Department inspections have passed. For Cobb County Building Department you may call 770-528-2077, after 8:00 a.m. <u>the day after all of your inspections have been made</u> to check on the status of your Certificate of Occupancy. Any inspections within the City limits of Acworth, Kennesaw or Powder Springs, you can contact them directly <u>the morning after</u> your fire inspection at the above listed numbers.